



GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



F O R M - (G)

Dated Guwahati the 31/10/2020

To,

The Principal,
Teachers Training College,
Mirza, Dist:- Kamrup (R), Assam.

NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN ***THE TEACHERS TRAINING COLLEGE AT MIRZA, DIST:- KAMRUP (R), ASSAM.***

With reference to your completion report under No. NIL Dated 26.02.2020 and on the basis of the inspection report submitted by Station Officer, Sukla Ram Boro on the building as per description below at Dag No. 1881 (O), 2607(N) Patta No. - Mouza Chayani, (Place- Mirza, Dist:- Kamrup (R)) in respect of implementation of Inbuilt Fire Fighting/ Fire Prevention/ means of escape measures as declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No objection in its occupation /utilization for the purpose of **COLLEGE** subject to condition mentioned over leaf.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area: - Block 'A' = 491.4 m², Block 'B' = 588 m²

2. Purpose of utilization: -

For Classroom & Others Activity rooms.

Details of Fire Fighting measures found in working condition:

1. Hose Reel Hose system
2. Down Comer system
3. Yard Hydrant system
4. Manually operated Electric Fire Alarm system
5. Fire Extinguishers- 15 Nos.
6. Underground Water Reservoir
7. Terrace Water Tank
8. Fire Pump

[Signature]
31.10.2020

Deputy Director,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

Dated Guwahati the _____

NO. F&ES/FPW/

Copy to:-

1. The Deputy Commissioner, **Kamrup (R)**, Assam for information and necessary action.
2. The President/ Secretary, **105 No. Kochpara Gaon Panchayat**, Assam for information and necessary action.
3. The Station Officer, **Mirza F&ES Station**, for information.

[Signature]
Deputy Director,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.